













	1 2	3	4	5	King
	LIGHTING FIXTURE SCHEDULE	ELECTRICAL SYMBOL LIST	MECHANICAL EQUIPMENT SCHEDULE	GENERAL NOTES:	MIII
	SYMBOL DESCRIPTION LATPS APPROVED MANUFACTURERS CATALOG NUMBER  4' MATER PROOF PUI'P ROOM LIGHT FIXTURE - DAY-BRITE DWA-E232-2711/2EB	SYMBOL DESCRIPTION LIGHTING SYMBOLS	NAME OF	THININUM SIZE OF CONDUIT TO BE 3/4". I/2" CONDUIT MAY BE USED FOR CONTROL CABLES, ALUMINUM CONDUITS SHALL NOT BE USED.	Engineering,
	T-I CHAIN HJNG, 2TT VOLT. 2F32	INDUSTRIAL STRIP LIGHT  HALL MOUNTED FIXTURE	MECHANICAL EQUIPMENT &	② USE RIGID STEEL SET SCREW TYPE FITTINGS ONLY. DIE CAST FITTINGS SHALL NOT BE USED.	2825 E Cottonwood Parkway Salt Lake City, Utah 84121
	EXTERIOR HALL MOUNTED LIGHT FIXTURE HITH BUILT IN PHOTO CELL. 211 VOLT.  NITE-BRITE  MCS-IOOM-DT-LP/PEC-HIT  NO MH	WALL MOUNTED FIXTURE  EXIT LIGHT. ARROWS SHOW EXIT DIRECTION	EVM	3 ALL NEW WORK MUST MEET THE CURRENT ADOPTED NATIONAL ELECTRICAL CODE.	Phone: 801.990.3170 Fax: 801.990.3293
Б	ТН	B'ERGENCY BATTERY OPERATED LIGHT-SINGLE OR TWIN BEAM	EQUIPTENT NO.   P-I,2	NOT MORE THAN THREE (3) CIRCUITS, SHALL BE INSTALLED IN A 3/4" CONDUIT.  THE SIZE OF THE NEUTRAL CONDUCTORS SHALL BE NO. 10 AWG FOR ALL HOME	Internet: www.pavementmanagement.com
D	PANEL "LP1" AIC RATING 10K AMPS	LIGHTING FIXTURE CALLOUT. NUMBER INDICATES A SUGGESTED QUANTITY- TO BE VERIFIED  REFERENCE NOTE CALLOUT	VOLTAGE 460	RUNS WITH COMMON NEUTRAL (LIGHTING AND POWER CIRCUITS).  (6) THE MINIMUM SIZE OF THE CONDUCTORS ARE TO BE #12 ANG THIN COPPER,	CREATED BY: KING ENGINEERING, INC.
	PHASE / WIRE         3 / 4           MAN LUG         AMPS           MAN BREAKER         20           MAN'S         COMMENT           IG	\$ SINGLE POLE TOGGLE SHITCH - 20 AMP	PHASE 3	UNLESS INDICATED OTHERWISE ON THE DRAWINGS.  DETAILS ARE SHOWN ON DIFFERENT SHEETS. THE CONTRACTOR SHALL REFER	
	CKT LOCATION RECEPT LTG OTHER POLE SIZE PHASE SIZE POLE OTHER LTG RECEPT LOCATION CKT 1 GFLOUTLETS 1 20 A 20 1 SPARE 2		4 NIRE SIZE 3 #8	TO THOSE DETAILS WHETHER OR NOT CALLED IN REFERENCE NOTES.  B ALL J-BOXES SHALL HAVE MINIMM DEPTH OF 2-1/8" UNLESS OTHERWISE	ELECTRICAL CONCILIE TIMO FAIGNIFFEDO INC
	3 CONTROL PANEL 1 20 B 20 1 SPARE 4 5 FUTURE HEATER 1 20 C 20 1 SPARE 6 6 7 7 SPARE 1 20 A 20 1 SPARE 8	DUPLEX CONVENIENCE CUTLET - 20 APP GROUND FAULT INTERRUPTER	GROUND WIRE 1 18	SPECIFIED. SECURE ALL J-BOXES AS SHOWN IN THE DETAILS. FURNISH AND INSTALL PROPER MUD RINGS.	ELECTRICAL CONSULTING ENGINEERS INC. 939 SQ. WEST TEMPLE PHONE: (801) 522-8007
	9 SPARE 1 20 B 20 1 SPARE 10 11 12 13 14 14	UNINCTION BOX - SIZE AND FUNCTION AS REQUIRED  - ## — CONDUITS CONCEALED IN FLOOR OR BELOW GRADE	CONDUIT SIZE 3/4"	ALL NEW EXPOSED CONDUIT MUST RUN AGAINST THE WALLS OR CEILINGS. DO NOT PENDANT MOUNT ANY CONDUIT FROM THE CEILINGS.	SLC, UTAH 84101 FAX: (801) 521-8057
	15 16 17 18	CONDUITS CONCEALED IN CEILING AND WALLS	TYPE RKI FUSES 50	ALL THE HOMERINS MUST BE ACCESSIBLE. DO NOT CARRY A HOMERUN FROM ONE DEVICE TO ANOTHER WHICH IS TIED TO A SEPARATE HOMERUN INSIDE THE WALL, MARK ON ALL THE J-BOYES THE CIRCUIT NATES AND MUMBERS, USE NO.	ROTESSIONAL NO.
_	19 20 21 22 23 24	ARROWS INDICATE HOME RUINS - LINES INDICATE NUMBER CONDUCTORS  (9) MOTOR LOCATION	NON-FUSE SH	MALL. TIARS ON ALL THE J-BOXES THE CIRCUIT NATES AND NUTBERS, USE NO. 10 THAN CONDUCTORS FOR HOMERUNS OVER 100 TEET, NO. 8 THAN OVER 200 FEET AND NO. 4 THAN OVER 400 FEET LENGTH.	Sy/334543-2202\ MANSOUR AGHDASI
	25 26 27 28 28 29 30 30	XX-I MECHANICAL EQUIPMENT CALLOUT	NOTES   1	USE EPOXY ANCHORS TO SUPPORT THE ELECTRICAL EQUIPMENT. EXPANSION ANCHOR BOLTS ARE NOT ACCEPTED.	TATE OF VIEW
	31 32 33 34 34 36 9 9 9	ELECTRICAL PANEL LOCATION  ELECTRICAL METER LOCATION	NOTES:  1. STARTER IS FURNISHED WITH THE UNIT. PROVIDE SITE DISCONNECT.  2. PROVIDE THERTIAL OVERLOAD SHITCH.	12) AT THE BND OF THE JOB, PROVIDE BLANK COVER PLATES TO MATCH THE OTHER COVER PLATES FOR ALL J-BOXES WHERE DEVICES HAVE NOT YET BEEN	SITE/LOCATION:
	37 38 38 40 47	WP INDICATES MEATHER PROOF ENCLOSURE		(3) SEAL AROUND ALL CONDUIT PENETRATIONS THROUGH WALLS AND CEILINGS	JORDAN RIVER
	41 VA VA AMPS KVA VA VA VA VA O O O O O O O O O O O O O			WITH FIRE RATED MATERIAL. 3M IS AN APPROVED MANUFACTURER.  ALL MATERIALS USED IN THIS INSTALLATION SHALL BE ULL. APPROVED AND NEW.	OHV PARK
	0 0 0 B 0 B 0 0 0 0 0 0 0 0 0 0 0 0 0 0			(5) ALL ELECTRICAL WIRING MUST BE IN CONDUIT (ROMEX NOT PERMITTED). (16)	DEVELOPMENT
C				NO CONDUITS SHALL RUN IN DUCT WORK.  TEMPORARY ELECTRICAL SERVICE IS TO BE PROVIDED BY THE ELECTRICAL	C
	PANEL         'HP1'         AIC RATING         22K         AMPS           PHASE / WIRE         3 / 4         RATING         277 / 480         VOLTS			CONTRACTOR AND REMOVED BY THE ELECTRICAL CONTRACTOR.  (B)  THE ELECTRICAL CONTRACTOR SHALL TERMINATE THE ELECTRICAL	
	MAIN LUG         AMPS         SUBFEED LUGS         YES           MAIN BREAKER         200         AMPS         COMMENT         IG			CONNECTIONS TO ALL THE EQUIPMENT BY PROVIDING THE NECESSARY MALE/FBMALE CONNECTOR, RECEPTACLE, PLUG, ETC.	
	CKT         LOCATION         RECEPT         LTG         OTHER         POLE         SIZE         PHASE         SIZE         POLE         OTHER         LTG         RECEPT         LOCATION         CKT           1         10,0000         A         1300         SYMATRANS FEEDING         2           3         10,0000         B         1300         SKYMATRANS FEEDING         4			ALL DUPLEX OUTLETS AND SWITCHES SHALL BE 20 AMP, 120 VOLT SPEC GRADE. HUBBELL AND PASS & SEMYOUR AND LEVITON ARE APPROVED MANUFACTURERS.	
	6 PUMP P-1 10,000 3 50 C 20 3 1300 PANEL*\(\text{LYPT}\) 6 7 10,000 A 20 1 500 LIGHTING 8 9 10,000 B 20 1 500 LIGHTING 8			THE ELECTRICAL CONTRACTOR SHALL NOTIFY AND COORDINATE WITH THE HECHANICAL CONTRACTOR SO THAT NO PIPING, DUCTS, OR OTHER EQUIPMENT	DD O INCCT THE I
	9 10,000 B 20 1 SPARE 10 11 PUMP P-2 10,000 3 50 C 20 1 SPARE 12 13 A 20 1 SPARE 14			SHALL BE INSTALLED IN ENTRY OR PASS THROUGH ELECTRICAL ROOM OR SPACES ABOVE OR BELOW ELECTRICAL PANELS.	PROJECT TITLE:
	15   B 20 1   SPARE   16   17   SPARE   18   19   SPARE   18   19   SPARE   4   20 1   SPARE   20   19   SPARE   20   SPARE   20			ELECTRICAL CONTRACTOR SHALL VERIFY ALL ELECTRICAL LOADS (VOLTAGE, FHASE, CONNECTION REQUIREMENT, ELOT) OF EQUIPMENT FURNISHED UNDER OTHER DIVISIONS WITH APPROVED SHOP DRAWINGS. REFER TO BEGINNING	NEW MOTOCROSS
_	21 23 25			OTHER DIVISIONS WITH APPROVED SHOP DRAWNINGS. REPER TO BEGINNING ROUGH-IN.  PROVIDE TYPED LABEL FOR ALL DUPLEX OUTLETS AND LIGHT SWITCHES TO	TRACK AND
	27 29 31			INDICATE WHICH CIRCUIT THEY ARE TIED TO.	IRRIGATION   SYSTEM
	33 35 37				STSTEIN
	39 41	PANEL NEW 25' POWER POLE ACROSS "LPI" THE RIVER BY CONTRACTOR.	CROSS BRACKET WITH ISOLATORS TRANSITION AND LIGHTNING		
	VA VA VA AMPS KVA VA VA VA VA 0 0 20000 A 787 A 218 A 1800 0 0 0 0 20000 B 789 B 213 B 1300 0 0	I20/208V. PROPERLY SUPPORT THE POLE TO MEET UP \$1.5 STANDARD.— (5)	ARRESTORS RATED NEW POWER POLE AND ACSR CABLES FOR 200A, (TYPICAL) TRASHFORTER BY UP A	L. \ REDWOOD ROAD BY UP&L.	
	0 0 20000 C 769 C 213 C 1300 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	5KVA	VEN RATED FOR JA	EXISTING POWER POLE ACROSS THE STREET.	
В		# 3/0   H 6	ORS TRANSITION 4# 3/0 4# 3/0 GUY WIRE		В
		3 #12 2'C / ARREST. FOR 20. 34*	ORS RATED 2°C     \		
		77'  — conduit conduct	AND CONTRACTOR. CT CAN WP WITH	CONDUIT BY CONTRACTOR.	
		PANEL "IFF" GUY WIRE			
		277/480V. 30, 4H. # 6	4\$ 3/O		3/16/06
		220	200		MARK DATE DESCRIPTION ISSUE TYPE: FINAL
_		COLD MATER		\$	ISSUE DATE: MARCH 31, 2006
			47/8/ COPPER ROUND ROD.  3/41/8/ COPPER GROUND ROD.	*2	DFCM PROJECT NO: 05261510
		5/8" X 8'-0" COPPER CLAD GROUND  ROOS BURIED 24" BELON GRADE	<u></u>	5/8" X 8'-0" COFPER CLAD GROUND RODS BURIED 24" BELON GRADE	ECE PROJECT NO: 3132 CAD DWG FILE: E-001,DWG
		EXOTHERNICALLY MELD ALL CONNECTIONS	2' DIAPETER X 6' HIGH POLE	EXOTHERMICALLY WELD ALL CONNECTIONS	DRAWN BY: JB
			BURIED IN CONCRET.  DESERVED IN A OFFICE.		CHK'D BY: MA COPYRIGHT:
		POWER SINGLE LINE	REFERENCE NOTES:  ◇ FURNISH AND INSTALL NEW POWER POLES AND OVER HEAD.		SHEET TITLE
		SCALE: NT.9.	ALL NECESSARY BRACKETS, INSTILLATORS, LIGHTING ARESSTORS, GUYWIRES, ETC., FOR A COMPLETE INSTALLATION.		SCHEDULES & POWER
A			THE INSTALLATION SHALL MEET UP & L'S STANDARD. PROPERLY GROUND EACH POLE. RUN THE GROUND CONDUCTOR ALL THE WAY TO THE BRACKET.		A  SINGLE LINE DIAGRAM
			MOUNT THE C.T. CAN/DISCONNECT ON A UNISTRUT.  COORDINATE WITH THE LOCAL POWER COMPANY AND INCLUDE		CHEET M. P. COET
			ALL NECESSARY LABOR AND MATERIAL FOR A COMPLETE INSTALLATION.		SHEET NUMBER
					E-001
					L-001
	1 2	3	4	5	SHEET 8 OF 9
B-EX					1 5 0 0, 0

